

Provided By:

Thermco Energy Systems

74 Chula Brookfield Rd, Chula, GA 31733

Phone (904)424-9773

Website: www.Thermcoenergysystems.com

Email: Info@Thermcoenergysystems.com

Blower Performance Data

Model No.		Min. CFM	External Static Pressure (in. of wg.)						
			0.2	0.3	0.4	0.5	0.6	0.7	0.8
HPX024	High		1040	983	926	884	827	751	675
	Medium		931	884	836	798	746	675	
	Low	720	846	798	751	713	665		
HPX031	High		1288	1230	1172	1110	1037	965	893
	Medium		1168	1110	1052	1004	936	869	801
	Low	800	1062	1004	946	907	840	782	
HPX036	High		1275	1218	1160	1098	1027	955	917
	Medium		1156	1098	1041	993	926	912	
	Low	960	1051	993	935	917			
HPX041	High		1444	1387	1330	1273	1221	1150	1078
	Medium	1144	1245	1207	1169	1116	1045		
HPX048	High		1935	1920	1906	1901	1872	1834	1795
	Medium		1433	1409	1385	1380	1375	1361	1346
	Low	1280	1274	1269	1264	1245	1226		
HPX060	High		2246	2189	2131	2064	1968	1795	1622
	Medium		2016	1968	1920	1862	1776	1622	1488
	Low	1584	1805	1766	1728	1670	1594	1488	